

SEM3-M/WL-2L

Multi-function 3-phase energy meter



- Multi-parameter measurements
- Accuracy Class 1 active energy
- Wi-Fi available (SEM3-WL only)
- RS485 Modbus RTU
- Modbus TCP (SEM3-WL only)
- 2 Measurement modes
- Easy connection solution
- Compact design
- Support 1x3p or 3x1p load measurements
- Phase sequence error warning
- Phase sequence switchable
- Current Reverse Setting
- Four-quadrants reactive energy

USER MANUAL
2026 V1.03

Statements

All rights reserved. Without the written permission of the company, no paragraphs or chapters in this manual can be extracted, copied or reproduced in any form. Otherwise, the violator shall bear all consequences.

Eastron reserves all legal rights.

Eastron reserves the right to amend the product specifications in this manual without prior notice. Before placing an order, please contact our company or local agent to get the latest specifications.

CONTENT

Version History	1
Risk Information	2
Chapter 1. Introduction	4
1.1 Product Introduction	4
Chapter 2. Technical Parameters	5
2.1 Specifications	5
2.2 Marking	8
2.3 Dimensions	8
2.4 Mounting	9
2.5 RJ12 Terminal Definition	10
2.6 Wiring Diagram	10
Chapter 3. Operation	12
3.1 Operation of Wi-Fi Communication	12
3.2 Definition of Button and LEDs	16
3.3 Maintenance	17

Version History

Version	Date	Changes
1.00	2025-10-29	Initial issue
1.01	2025-11-03	Optimize some words and sentences
1.02	2026-06-17	Revise the illustration in the WiFi provisioning chapter; Change the laser drawing and Dimension drawing
1.03	2026-06-23	Change current parameters

Risk Information

Information for Your Own Safety

This manual does not contain all of the safety measures operating the equipment (module, device) for different conditions and requirements. However, it does contain information which you must know for your own safety and to avoid damages. This information is highlighted by a warning triangle, which indicates the degree of potential danger.



Warning

This means that failure to observe the instruction can result in death, serious injury or considerable material damage.



Caution

This means hazard of electric shock and failure to take the necessary safety precautions will result in death, serious injury or considerable material damage.

Qualified personnel

Operation of the equipment (module, device) described in this manual must only be performed by qualified personnel. Qualified personnel in this manual means people who are authorized to commission, start up, ground and label devices, systems and circuits in accordance with Safety Regulatory standards.

Proper handling

The prerequisites for perfect, reliable operation of the product are proper transport, storage, installation and operation and maintenance. When operating electrical equipment, some parts of this equipment automatically carry dangerous voltages. Improper handling can therefore result in serious injuries or material damages.

- ✧ Use only insulating tools.
- ✧ Do not connect while circuit is live (hot).
- ✧ Place the meter only in dry surroundings.
- ✧ Do not mount the meter in an explosive area or expose the meter to dust, mildew and insects.
- ✧ Make sure the wires are suitable for the maximum current of this meter.
- ✧ Make sure the AC wires are connected correctly before activating the current/voltage to the meter.
- ✧ Do not touch the clamps directly with metal, blank wire or your bare hands as you may get electrical shock.
- ✧ Make sure the protection cover is placed after installation.
- ✧ Installation, maintenance and reparation should only be done by qualified personnel.
- ✧ Never break the seals or open the front cover as this might influence the function, and will void the warranty.
- ✧ Do not drop, or allow strong physical Hit on the meter as the high precisely components inside may be damaged.
- ✧ This product is designed to be mounted inside of switchboards or cabinet on DIN rail.
- ✧ This device must have a suitable sized Circuit Breaker feeding the Multi Function Energy Meter so it does

not exceed the maximum rated current.

- ✧ The supply wiring of this device shall be suitable sized cable to match the installed circuit breaker.
- ✧ A Disconnection Device (Circuit Breaker) should be installed close to the Multi Function Energy Meter.
- ✧ The Disconnection Device shall be marked as the Disconnection Device for the Multi Function Energy Meter.

Disclaimer

We have checked the contents of this publication and every effort has been made to ensure that the descriptions are as accurate as possible.

However, deviations from the description cannot be completely ruled out, so that no liability can be accepted for any errors contained in the information given. The data in this manual is checked regularly and the necessary corrections are included in subsequent editions. We are grateful for any improvements that you suggest.

Chapter 1. Introduction

1.1 Product Introduction

Eastron SEM3 Series is a new generation din rail mounted energy meter, equipped with Wi-Fi and RS485 connectivity. With multi parameters measurement, SEM3 can be used for energy monitoring of various applications, such as PV energy management, smart building, industrial equipment, etc. The meter can be used as a 3-phase energy meter or 3 individual single phase energy meters. In single phase mode, 3 external CTs can be set with different CT ratio for three independent loads.

Eastron SEM3 measures and displays the characteristics of 1P2W, 1P3W, 3P4W and 3P3W supplies, including voltage, frequency, current, power, active and reactive energy, imported or exported, power factor, Max. demand etc. Energy is measured in kWh, kVAh and kVAh. It provides 4 quadrant measurement.

Eastron SEM3 is designed in compact size. To save installation and maintenance costs, all terminals of SEM3 adopt spring terminals or RJ terminals for easy connection. Warning is also available in case the phase sequence error happens.

Eastron SEM3 provides two measurement modes: Total mode and PV mode. In total mode, import and export energy will be measured separately. In PV mode, import and export energy will be balanced first, and the balanced value will be counted in import or export energy.

Chapter 2. Technical Parameters

2.1 Specifications

Table 1

Electrical Characteristics		
Type of Measurement		RMS Including Harmonics on Three Phase AC System (3P, 3P+N)
Measurement Accuracy	Voltage	± 0.5%
	Current	± 0.5%
	Frequency	± 0.1%
	Power Factor	± 0.01
	Active Power	± 1% IEC 61557-12 Class 1
	Reactive Power	± 1% IEC 61557-12 Class 1
	Apparent Power	± 1% IEC 61557-12 Class 1
	Active Energy	± 1%
	Reactive Energy	± 2%
Data Update Rate		Active Power: Channel 1: 50mS(RS485), 100mS(Wi-Fi) Channel 2: 100mS(RS485), 150mS(Wi-Fi)
Technical parameters	Voltage AC (Un)	3*230V(L-N)/400V(L-L)
	Voltage Range	100-277 V AC (L-N) 173-480 V AC (L-L)
	Current Input	8mA
	Maximum Current	40mA
	Minimum Current	0.4mA
	Starting Current (Ist)	0.032mA
	Transition Current (Itr)	0.8mA
	Over Current Withstand	30Imax for 0.01S
	AC Voltage Withstand	4KV/1min
	Impulse Voltage Withstand	6kV – 1.2/50μS waveform
	Voltage Circuit Power Consumption	≤ 2W/10VA
	Current Circuit Power Consumption	≤0.05VA
Mechanical Characteristics		
Weight		≈ 100g
IP Degree of Protection (IEC 60529)		IP51 Front Display IP20 Whole Meter
Dimensions (DxHxW)		94*19*68.5mm
Mounting		DIN Rail 35mm
Material of Meter Case		Self-extinguishing UL 94 V-0
Mechanical Environment		M1
Environmental Characteristics		
Operating Temperature		-40℃ ~ +70℃
Storage Temperature		-40℃ ~ +80℃
Operation humidity		≤90% Non-condensing
Storage humidity		≤95% Non-condensing
Pollution Degree		II

Altitude	≤2000m
Vibration	10Hz ~ 50Hz, IEC 60068-2-6
Electromagnetic Compatibility	
Electrostatic Discharge	IEC 61000-4-2
Immunity to Radiated Fields	IEC 61000-4-3
Immunity to Fast Transients	IEC 61000-4-4
Surge (Impulse) Immunity	IEC 61000-4-5
Conducted Immunity	IEC 61000-4-6
Immunity to Magnetic Fields	IEC 61000-4-8
Immunity to Voltage Dips	IEC 61000-4-11
Radiated Emissions	CISPR 32
Conducted Emissions	CISPR 32
Safety	
Measurement Category	Per IEC61010-1 CAT III
Current Inputs	Require External Current Transformer for Insulation
Installation Category	CAT III
Over-voltage Category	CAT III
Protective Class	II
Interface 1	RS485
Interface 1 Protocol	MODBUS RTU
Communication Address	1 to 247
Transmission Mode	Half Duplex
Data Type	Floating Point
Transmission Distance	1000m Maximum
Transmission Speed	2400/4800/9600(Default)/19200/38400/115200bps
Parity	NONE(Default)/ ODD / EVEN
Stop Bits	1 or 2
Response Time	<50 ms
Interface 2	Wi-Fi
Interface 2 Protocol	MODBUS TCP
Data Type	Floating Point
RF Band	2.4 GHz to 2.5 GHz
Max. RF Power	<20 dBm
Wi-Fi Protocol	802.11 b/g/n
Wi-Fi Range	Up to 30m / 100ft indoors and 50m / 160ft outdoors (Depends on local conditions)

Table 2

Note: ● = included
 — = excluded


Features	Models	
	SEM3-WL-2L	SEM3-M-2L
Instantaneous Measurements		
Current	●	●
Voltage L-N	●	●
Voltage L-L	●	●
Frequency	●	●
Active Power	●	●
Reactive Power	●	●
Apparent Power	●	●

Power Factor	•	•
Energy Values		
Active Energy	•	•
Reactive Energy	•	•
Apparent Energy	•	•
Demand Values		
Current	•	•
Active Power	•	•
Reactive, Apparent Power	—	—
Maximum Demand Values		
Maximum Current	•	•
Maximum Active Power	•	•
Maximum Reactive Power	—	—
Maximum Apparent Power	—	—
Power-Quality Values		
Total Harmonic Distortion	•	•
Individual Harmonic Distortion	—	—
Network		
1 Phase 2 Wires	•	•
1 Phase 3 Wires	•	•
3 Phase 3 Wires	•	•
3 Phase 4 Wires	•	•
CT Programmable	•	•
PT Programmable	—	—
Inputs and Outputs		
Alarms	•	•
Communications		
RS485	•	•
Wi-Fi	•	—


Technical Standards:

- [1] EN IEC61326-1: 2021 Electromagnetic Compatibility Directive - Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements
- [2] EN IEC 61326-2-3: 2021 Electromagnetic Compatibility Directive
- [3] EN61010-1:2010+A1:2019 Low Voltage Directive 2014/35/EU - Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements
- [4] EN61010-2-030:2010 Low Voltage Directive 2014/35/EU - Particular requirements for testing and measuring circuits
- [5] EN 50470-3:2022 Electricity metering equipment - Part 3: Particular requirements - Static meters for AC active energy (class indexes A, B and C)
- [6] IEC62053-21:Electricity metering equipment - Particular requirements - Part 21: Static meters for AC active energy (classes 0,5, 1 and 2)

2.2 Marking




(SEM3-WL-2L nameplate and laser printing)



(SEM3-M-2L nameplate and laser printing)

2.3 Dimensions




2.4 Mounting

Step 1: Select a 35mm-wide DIN rail, Pull down the back-end clip on the meter to unlock the mounting mechanism.


Step 2: Align Upper Slot with DIN Rail. Position the upper slot of the meter's DIN rail groove onto the DIN rail, ensuring full contact (see Figure 1).

Step 3: Following the direction indicated in Figure 1, engage the lower slot of the DIN rail groove onto the DIN rail until audibly seated (see Figure 2).


Step 4: Push up the back-end clip to lock the meter firmly onto the DIN rail (see Figure 3).




2.5 RJ12 Terminal Definition

Interface	Definition
	1.Brown: I_A+
	2.White: I_A-
	3.Black: I_B+
	4.Orange: I_B-
	5.Red: I_C+
	6.Yellow: I_C-

2.6 Wiring Diagram






Chapter 3. Operation

3.1 Operation of Wi-Fi Communication

SEM3-WL-2L comes with built-in Wi-Fi functionality. When it is powered on, the three LEDs on the front panel will flash and self-check program will start. If everything is normal, the Wi-Fi indicator will light up blue, and the meter will enter AP mode, with the AP name formatted as "EM-serial number".



User can search all available Wi-Fi AP by PC or Phone, in which the AP of the meter is listed. For example:



Double click the AP of the meter "EM-240460817", and enter the password to establish the connection. Default password is the same as serial number, i.e. 240460817.

After a successful connection, the user can access the meter's built-in web server by entering 192.168.4.1 in a browser.

The web-server including 4 pages: Data Sync, Data Sync2, Setting and OTA (Over-The-Air Technology).


Data Sync: The data will be read instantaneously.



Setting: set up Wi-Fi of the energy meter in AP mode and in station mode.

After a successful connection, the user can configure the meter to station mode and connect it to another available Wi-Fi network. The specific steps are as follows:

1. Set Mode to Station: On the settings interface, select "Station" as the operating mode.
2. Select Network: Choose your desired Wi-Fi network from the available list.
3. Enter Password: Input the password of the selected network to establish the connection.




Wi-Fi Connection Status Indicator


During the connection process, the Wi-Fi LED on the meter's front panel will flash continuously. A successful connection is indicated when the LED stops flashing and remains steadily lit.

Retrieving Meter Information Using MDNS


The user can use MDNS (Multicast DNS) to retrieve the meter's information, including its IP address, Serial Number (SN), MAC address, and model. If multiple meters are on the same network, MDNS will list the information for all of them.



OTA: update the firmware of the meter over-the-air.



3.2 Definition of Button and LEDs

Interface	Definition	Introduction
	1.Power LED (Red)	1.Stay on: Light up when the meter is powered on with no load. 2.Flashing: Blinks when a load is connected.
	2.RS485 LED (Green)	1.Stay on: During the OTA upgrading. 2.Flashing: Blinks when the meter is communicating normally.
	3.Wi-Fi LED (Blue) (Only for SEM3-WL-2L)	In the AP mode: 1.Stay on: Light up when the meter enters the AP mode. 2.Flashing: Blinks when the meter is disconnected to the network. 3.Off: Light off after the meter is connected to the network.
		In the station mode: 1.Stay on: Light up when the Wi-Fi module malfunctions. 2.Flashing: Blinks during the meter wireless communicating.
	4.AP Key	Press and hold for 3 seconds to enter/exit AP mode (Only for SEM3-WL-2L). Press and hold for 10 seconds to reset communication parameters.

***Phase sequence error warning:**

When the phase sequence is abnormal, all LED lights remain stay on;

(Note: Abnormal phase sequence state refers to incorrect connections in the voltage and current sampling lines, such as connecting the A-phase line to the C-phase line.)

***Parameter initialization:**

when initializing communication recovery by holding the button, all the lights stay on for 3 seconds as a prompt and then turn off.

3.3 Maintenance

Under normal operating conditions, electricity meters require only minimal maintenance. Depending on the actual working conditions, the power supply should be cut off before conducting equipment inspections and removing accumulated dust or foreign objects. It is necessary to regularly check the corrosion status of all connection terminals, which is particularly important in vibrating environments.

The front of the case should be wiped with a dry cloth only. Use minimal pressure, especially over the viewing window area. If necessary, wipe the case with a dry cloth. Water should not be used. If the case exterior or terminals should be contaminated accidentally with water, the unit must be thoroughly dried before further use. If there is any water ingress, factory inspection and refurbishment is recommended.

If the product requires repair, please kindly send it back to Eastron or Eastron's distributor.

IF you have any question, please feel free to contact our sales team.

Zhejiang Eastron Electronic Co., Ltd.

No.52, DongJin Rd. Jiaxing, Zhejiang, 314001, China

Tel: 400-996-9296 Fax: +86-573-83698883

Email: sales@eastrongroup.com

www.eastrongroup.com

